



City of Pikeville Fire Department

Food Truck Checklist

NFPA 1 & 96

104 Chloe Road

Pikeville, KY 41501

Tel: 606-437-5125

815 KAR 10:060 Requires That All Food Trucks comply with NFPA 1, 2018 ed.

- Hood & Exhaust System:
- Fire Suppression System
- Fire Extinguishers:
- Clearance:
- Main Shutoffs:
- Propane Secure:
- Training Completed:
- Portable Generators:
- Propane Leak Test:
- Piping Compliant:
- Appliances Listed:



Corrections Notes: _____

Compliant Y N

Food Truck Name/Owner: _____

Contact Info: _____

License Plate: _____

Inspector: _____

Fire Department: _____

Date: _____

Approved:	<input type="checkbox"/>
Denied:	<input type="checkbox"/>



City of Pikeville Fire Department

Food Truck Checklist

NFPA 1 & 96

104 Chloe Road

Pikeville, KY. 41501

Tel: 606-437-5125

Further Details:

All Food Trucks shall comply with NFPA 1, 2018 ed. And 815 KAR 10:060.

Hood & Suppression System: Approved, Installed, Inspected, Operational

Fire Extinguishers: One 2A:10BC Extinguisher Required, Class K if Fryer Present

15 ft. Clearance: From Buildings, Combustibles, other Cooking Operations. Exemptions must be approved by AHJ.

Main Shutoffs: Present, Unobstructed, Sign in Reflective Decal Material 2 inches Height

Propane Secure: Cylinders Secured Upright with Tip Prevention in Approved Location and Vented

FD Access Provided: Units Shall Not Block Fire Lanes, Hydrants, or Access Training

Required: Workers Shall be Trained in Emergency Procedures:

- Use of portable fire extinguishers and extinguishing systems
- Proper method of shutting off fuel sources
- Proper procedure for notifying the fire department
- Proper refueling
- How to perform leak detection
- Fuel properties

Portable Generators: Exhaust 5 ft. Away from Openings, Air Intakes, Egress

Propane Leak Test: Name of Company, Date of Test, "The LP Gas system has been inspected for compliance with the current edition of NFPA 58 and found to be in compliance with the provisions of the code. In addition, leak detection has been conducted on the LP-Gas system piping and the piping has been found to maintain integrity"